



10500 W. 167<sup>th</sup> Street Orland Park, IL 60467 • Phone: 708/460-1800 • Fax: 708/460-2993

Aug 11, 2006

Ed Pivonka  
IDEAL INDUSTRIES, INC.  
9650 Chesapeake Drive  
San Diego, CA 92123

Dear Ed,

This letter is to inform you that Panduit has approved LANTEK 6/6A/7/7G to be used in testing PANDUIT's copper connectivity solutions for both Channel and Permanent Link tests with the following requirements:

- IDEAL INDUSTRIES Category 6/5e adapter RJ45 (Part # 0012-00-0629, #0012-00-0656).
- PANDUIT patch cord (Part # UTPSP\*).
- Firmware revision: 2.500 or later

Testing in our lab has found that the LANTEK 6/6A/7/7G show good correlation to a network analyzer on all of the Category 6 tests. This is necessary to verify the performance of PANDUIT's copper connectivity products in field installations.

PANDUIT also accepts the test results provided with this tester for all of PANDUIT's warranty programs.

Sincerely,

Michael Yuan  
Product Development Engineer  
Network Connectivity Group  
PANDUIT Corp.